

所在地 東京都新宿区霞ヶ丘町 3 - 2 付近

標尺	深度	層厚	柱状図	土質区分	色調	孔内水位／測定月日	標準貫入試験					N値	N値～深度図
							深 度	10cmごとの打撃回数			打撃回数／貫入量		
								0 ι	10 ι	20 ι			
1	2.90	2.90	埋土	暗茶褐色			60 / 5		60 / 5	360			
2	2.90	2.90	粘土質ローム	茶褐色	2.15	1 / 13	1 / 7	2 / 11	4 / 31	3.9			
3	2.90	2.90			3.15	1 / 19	1 / 12		2 / 31	1.9			
4	4.80	1.90	粘土	乳黄灰色	4.15	1 / 12		1 / 8	3 / 30	3			
5					4.45								
6	6.80	2.00	凝灰質粘土	乳黄白色	5.15	1 / 9	1 / 11	2 / 13	4 / 33	3.6			
7					5.48								
8	8.60	1.80	粘土質細砂	茶黄褐色	6.15	1 / 8	2 / 13	2 / 13	5 / 34	4.4			
9					6.49								
10	9.90	1.30	細砂	茶黄褐色	7.15	0 / 3	1 / 24	1 / 14	2 / 41	1.5			
11					7.56								
12	11.50	0.70	礫混り粘土質細砂	黄褐色	8.15	1 / 13		1 / 9	3 / 32	2.8			
13					8.47								
14	13.85	1.45	粘土質中細砂	暗黄灰色	9.15	1 / 13	1 / 7	2 / 13	4 / 33	3.6			
15					9.48								
16	15.70	0.80	粘土混り微細砂	黄褐色	10.15				17 / 30	17			
17					10.45	5	6	6					
18	17.00	1.30	微粒砂	暗黄褐色	11.15				10 / 30	10			
19					11.45	2	4	4					
20	19.10	2.10	シルト混り細砂	暗黄褐色	12.15				11 / 30	11			
21					12.45								
22	20.30	1.20	砂礫	褐暗灰色	13.15				17 / 30	17			
23					13.45	5	7	5					
24	20.30	1.20	シルト混り微細砂	暗黄褐色	14.15				27 / 30	27			
25					14.45	7	8	12					
26	20.30	1.20	シルト混り微細砂	暗黄褐色	15.15				22 / 30	22			
27					15.45	6	7	9					
28	20.30	1.20	シルト混り微細砂	暗黄褐色	16.15				48 / 30	48			
29					16.45	14	19	15					
30	20.30	1.20	シルト混り微細砂	暗黄褐色	17.15			17 / 23	60 / 23	78.3			
31					17.38	17	26	3					
32	20.30	1.20	シルト混り微細砂	暗黄褐色	18.15		39 / 7		60 / 17	106			
33					18.32	21							
34	20.30	1.20	シルト混り微細砂	暗黄褐色	19.15				60 / 30	60			
35					19.45	20	16	24					
36	20.30	1.20	シルト混り微細砂	暗黄褐色	20.15		30 / 5		60 / 15	120			
37					20.30	30							