

所在地 東京都新宿区新宿四丁目 1 付近

標	深	層	柱	土	色	孔内水位 / 測定月日	標準貫入試験					N	N値 - 深度図	
							深	10cmごとの打撃回数			打撃回数 / 貫入量			
								0	10	20				
尺	度	厚	図	質	調		度	10	20	30		値		
	0.30	0.30		埋土	黒灰	1.90 						0		
1				有機土	黒灰		1.15	1 / 30			1 / 30	1		
2							1.45						0.6	
3							2.15	1 / 50				1 / 50	0.7	
4	3.40	3.10		粘土	黄褐		2.65							
5							3.15	0 / 15	1 / 30		1 / 45			
6							3.60							
7	4.90	1.50		粘土	乳黄褐		4.15		自沈		0 / 30			
8							4.45							
9							5.15	0 / 15	1 / 25		1 / 40			
10	5.90	1.00		粘土	暗灰		5.55							
11							6.15	1 / 32			1 / 32			
12							6.47							
13	6.60	0.70		砂質粘土	緑灰		7.15				10 / 30	10		
14							7.45	2	4	4				
15							7.70	1.10						
16				砂質シルト	暗緑 暗灰		8.15	1 / 15		1 / 8	3 / 33	2.7		
17							8.48							
18							9.15	1 / 14	1 / 8	1 / 8	3 / 30			
19	9.00	1.30		シルト混り軽石	乳緑灰		9.45					3		
20							9.70	0.70						
21						10.15	0.45				33 / 30	33		
22	10.15	0.45		砂質シルト	暗灰	10.45	1	10	22		50			
23						11.15					50 / 30	50		
24						11.45	15	14	21					
25				細砂	暗青	12.15				38 / 30	38			
26						12.45	12	13	13					
27						13.15				25 / 30				
28	13.70	3.55		貝殻混り細砂	暗青	13.45	6	7	12		25			
29						14.15				31 / 30				
30						14.45	9	11	11					
31	14.60	0.90		シルト	暗青	15.15				16 / 30	16			
32						15.45	4	5	7					
33						16.15				19 / 30				
34				細砂	暗青	16.45	5	6	8		19			
35						17.15				29 / 30				
36	17.35	2.75				17.45	6	8	15					
37				細砂										

