

所在地 東京都新宿区榎町3-9-1 付近

標	深	層	柱	土	色	孔内水位 / 測定月日	標準貫入試験					N
							深	10 cmごとの打撃回数			打撃回数 / 貫入量	
								0	10	20		
尺	度	厚	図	質	調		度	10	20	30		値
1	1.50	1.50		盛土	暗褐	6/27 9/28 4.10 ▽ ▽ ▽	1.15	1	1 / 9	2 / 18	4 / 37	3.2
2				ローム	茶褐		1.52			2 / 12	4 / 32	3.8
3							2.15	1	1	12	33	2.7
4							2.47					
5	4.60	3.10					3.15	1 / 11	1 / 12	1	3 / 33	4
6				粘土	暗褐		3.48					6
7							4.15	1 / 11	2	1 / 9	4 / 30	9
8	5.70	1.10		細砂	暗青灰		4.45				6 / 30	30
9							5.15	2	1	3	30	36
10				砂礫	茶褐		5.45				9 / 30	188
11	7.00	1.30					6.15	2	3	4	30	65.2
12				砂礫	暗青灰		6.45				30 / 30	60
13	8.00	1.00					7.15	9	10	11	30	55.6
14							7.45					50
15						8.15	11	12	13	30	50	
16						8.45	50 / 8			50 / 8	50	
17						9.15					50	
18	14.45	6.45				9.23					50	
19						10.15	19	20	3	23	50	
20						10.38					50	
21						11.15	18	19	5	25	50	
22				11.40					50			
23				12.15	17	18	7	27	50			
24				12.42					50			
25				13.15	16	17	17	30	50			
26				13.45					50			
27	14.45			14.15	15	17	18	30	50			
28				14.45					50			