

所在地 東京都新宿区西新宿七丁目11付近

標 尺	深 度	層 厚	柱 状 図	土 質 区 分	色 調	孔 内 水 位 ／ 測 定 月 日	10 cmごとの打撃回数					N 値	標準貫入試験			
							深 度	10 cmごとの打撃回数			打撃回数／貫入量		N 値～深度図			
								0	10	20						
1	1.40	1.40		盛土	褐灰	10/22 3.16	1.15	2/9	2/15	1/11	5/35	4.3				
2				ローム	茶褐		1.50		1/12	1/7	2/11	4/30	4			
3							2.15									
4	3.75	2.35					2.45									
5				凝灰質粘土	褐灰		3.15	2/13	1/11	2/9	5/33	4.5				
6							3.48									
7							4.15	1/9	2/12	2/11	5/32	4.7				
8							4.47									
9	6.70	2.95		砂混り粘土	黄灰		5.15	1/15			3/35	2.6				
10							5.50			1/14	2/11	5/34	4.4			
11							6.15									
12	8.85	2.15					6.49									
13				微細砂	暗黄灰		7.15	2/13		2/9	6/32	5.6				
14							7.47									
15							8.15	1/12	1/8	2/13	4/33	3.6				
16	12.80	3.95					8.48									
17				粘土質細砂	暗黄灰		9.15				17/30	17				
18	13.55	0.75					9.45	4	6	7						
19							10.15	5/11		5/9	15/30	15				
20							10.45									
21				硬質シルト	暗灰		11.15				36/30	36				
22						11.45	8	12	16							
23	14.90	1.35				12.15	8	9	9							
24						12.45										
25				砂礫	暗黄灰	13.15				20/30	20					
26	15.95	1.05				13.45	5	6	9							
27						14.15	3/11		3/9	9/30	9					
28						14.45										
29				粘土質シルト	暗灰	15.15			7/2	60/22	81.8					
30	20.70	4.75				15.37	24	29								
31						16.15	1/9	2/11	3/11	6/31	5.8					
32						16.46										
33						17.15		5/11	5/9	13/30	13					
34						17.45	3									
35						18.15	3/12	3/9		10/31	9.7					
36						18.46										
37						19.15	2/9		5/13	10/32	9.4					
38						19.47										
39						20.15	3/11		4	6	13/31	12.6				
40																

